

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1010:100 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Monitor Dynamics, 9518 Ninth Street, Rancho Cucamonga CA 91730
Contact: Loren C. Gonzales (909) 944-3911

DESIGN: Model MDI SAFENET system. Central station service. Refer to listee's data sheet for detailed product description and operational considerations. System components:

MDM-100/CPU-386 series	Automation System
PPU-50/-IOO	Receiving Unit
WISE-50	Video display
FUJITSU DX2300/DX2400	Printer
RTU-IOO/-200	Transponders (DGP)

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a control unit for use with separately listed compatible control units, initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Burglary and other non-fire functions were not examined. Refer to listee's data sheet or installation instructions for compatible non-fire devices.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**